

January 21, 2003

CAL No. 3-02-001C

Mr. Lew Myers  
Chief Operating Officer  
FirstEnergy Nuclear Operating Company  
Davis-Besse Nuclear Power Station  
5501 North State Route 2  
Oak Harbor, OH 43449-9760

SUBJECT: UPDATE OF CONFIRMATORY ACTION LETTER 3-02-001B STATUS FOR  
DAVIS-BESSE NUCLEAR POWER STATION

Dear Mr. Myers:

On March 13, 2002, the Nuclear Regulatory Commission (NRC) issued Confirmatory Action Letter No. 3-02-001 regarding the reactor pressure vessel head degradation at the Davis-Besse Nuclear Power Station. On May 15, 2002, the NRC revised the Confirmatory Action Letter, to address the option of replacing the reactor pressure vessel head. The Confirmatory Action Letter documented six sets of commitments you intended to take prior to restart of Davis-Besse.

On December 24, 2002, the NRC provided a letter to you, documenting our understanding of the current status of each of the items. The purpose of this letter is to clarify the status of Confirmatory Action letter Issue No. 1 in that December 24, 2002 letter. As discussed between Mr. R. Fast of your staff and Mr. J. Grobe, Chairman of the Davis-Besse Oversight Panel on January 10, 2003, the enclosure to this letter details the status of CAL Issue No. 1, including our understanding of your planned actions regarding the quarantined material from the damaged reactor vessel head. Notify me if your understanding differs from that described in the enclosure.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter and its enclosures will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

If you have any questions regarding the information in this letter, please contact me at 630-829-9657, or John Grobe at 630-829-9637.

Sincerely,

**/RA/**

J. E. Dyer  
Regional Administrator

Docket No. 50-346  
License No. NPF-3

Enclosure: Confirmatory Action Letter Issue No. 1 Status

cc w/encl: B. Saunders, President - FENOC  
Plant Manager  
Manager - Regulatory Affairs  
M. O'Reilly, FirstEnergy  
Ohio State Liaison Officer  
R. Owen, Ohio Department of Health  
Public Utilities Commission of Ohio  
President, Board of County Commissioners  
Of Lucas County  
President, Ottawa County Board of Commissioners  
D. Lochbaum, Union Of Concerned Scientists

DOCUMENT NAME: G:\DRP\Davis-Besse 0350\ML0302201650.wpd

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RIII	E	RIII		RIII	E	NRR	E
NAME	DPassehl/klg/ <b>/RA/</b>		CLipa <b>/RA/</b>		BClayton <b>/RA/</b>		WDean <b>/RA by CL via tel-con/</b>	
DATE	01/17/03		01/17/03		01/17/03		1/17/03	
OFFICE	RIII	E	NRR		RIII		RES	
NAME	JGrobe <b>/RA/</b>		SCollins <b>/RA by CL via tel-con/</b>		JDyer <b>/RA/</b>		Mayfield <b>/RA by CL via email/</b>	
DATE	1/17/03		1/17/03		1/21/03		1/21/03	

**OFFICIAL RECORD COPY**

ADAMS Distribution:

AJM

DFT

SPS1

RidsNrrDipmlipb

GEG

DMC

HBC

CST1

C. Ariano (hard copy)

DRPIII

DRSIII

PLB1

JRK1

DB0350

### **Confirmatory Action Letter Issue No. 1 Status**

"Quarantine components or other material from the RPV [Reactor Pressure Vessel] head and CRDM [Control Rod Drive Mechanism] nozzle penetrations that are deemed necessary to fully address the root cause of the occurrence of degradation of the leaking penetrations. Prior to implementation, plans for further inspection and data gathering to support determination of the root cause will be provided to the NRC for review and comment."

#### Status

Applicable components and material have been adequately quarantined and plans for inspection and data gathering to support root cause determination have been provided to the NRC for review and comment. Following discussions between Mr. R. Schrauder of your staff and Mr. W. Dean, Vice Chairman of the Davis-Besse Oversight Panel on November 1, 2002, it is our understanding that the following additional specimens will be removed from the damaged reactor vessel head:

- 1) Approximately 8 inches diameter of head material unaffected by heat around CRDM penetration Nozzles 2 and 46,
- 2) Nozzle base material from any two of Nozzles 1, 2, 4, or 5 (heat no. M3935),
- 3) Nozzle base material from Nozzle 47 (heat no. C2649-1), and
- 4) Nozzle base material from any two of Nozzles 7, 12, 16, 20, 22-25, 27-29, 38-44, 48-55, 57, 64, 68, or 69 (heat no. C2649-1).

The nozzle base material will be cut off both at the head and below the bimetallic weld, resulting in pieces about 7 to 8 inches long. The point of contact for the shipments of these specimens to Argonne National Laboratory (ANL) is Mr. William Cullen, Jr., Senior Materials Engineer, Materials Engineering Branch, Office of Research (RES). Mr. Cullen can be reached at 301-415-6754. Following removal of the material described above, and its shipment to ANL, the NRC releases the head from quarantine. With respect to the specimen materials sent to Lynchburg, Virginia, the quarantine will be considered lifted once the Phase 3 test plan for the material has been completed. The specimen material sent to Canada is now considered released from quarantine.